

**2023-2025 Lead Water Testing****Forts Ferry****DATE:**

1/18/2024

Sample #	Location	Time	Result	Acceptable range Pb
5	kitchen sprayer by dishwasher	425	7.9	≤ 5
6	kitchen sink next to freezer	426	10.5	≤ 5
13	FACULTY MENS left	433	11	≤ 5
24	room 22 bath left	442	5	≤ 5
25	room 22 bath right	442	12.9	≤ 5
26	room 23 sink	443	8	≤ 5
31	room 29 sink	454	5.6	≤ 5
32	room 29 bubbler	454	6.2	≤ 5
37	room 32 sink	459	8.5	≤ 5
38	room 32 bubbler	501	5.8	≤ 5
39	room 33 sink	504	10.1	≤ 5
73	room 9 fountain	537	6	≤ 5
75	room 8 fountain	540	15.9	≤ 5
76	room 8 bath left sink	541	7.1	≤ 5
77	room 8 bath right sink	541	7.4	≤ 5
80	room 7 fountain	545	6.3	≤ 5
82	room 6 fountain	546	14.9	≤ 5
84	room 5 fountain	549	8	≤ 5
87	room 4 fountain	551	9.9	≤ 5
91	room 2 bath sink	554	5.2	≤ 5
93	room 1 bubbler	558	6.9	≤ 5
94	room 1 bath sink	558	5.4	≤ 5