



**Experience is the solution**

314 North Pearl Street ♦ Albany, New York 12207  
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

January 25, 2024

Alan Levitus  
North Colonie Central School District  
735 Watervliet Shaker Rd  
Latham, NY 12110  
TEL: (518) 785-5771

Work Order No: 240119002  
PO#: 52078

RE: Lead in PW  
Forts Ferry

Adirondack Environmental Services, Inc received 98 samples on 1/19/2024 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

A handwritten signature in cursive script that reads "Tara Daniels".

Tara Daniels  
Laboratory Director

---

**North Colonie Central School District**

**Date:** 25-Jan-24

Lead in PW

Forts Ferry

**Lab WorkOrder:** 240119002

---

Sample containers were supplied by Adirondack Environmental Services.

---

**Definitions - RL: Reporting Limit DF: Dilution factor**

---

<b>Qualifiers:</b> ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

**Note : All Results are reported as wet weight unless noted**

---

**The results relate only to the items tested. Information supplied by the client is assumed to be correct.**

---

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-001 **Collection Date:** 1/18/2024 4:22:00 AM  
**Client Sample ID:** FF 1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	3.1	1.0		µg/L	1	1/24/2024 3:19:09 PM

**Lab SampleID:** 240119002-002 **Collection Date:** 1/18/2024 4:22:00 AM  
**Client Sample ID:** FF 2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	2.5	1.0		µg/L	1	1/24/2024 3:29:54 PM

**Lab SampleID:** 240119002-003 **Collection Date:** 1/18/2024 4:22:00 AM  
**Client Sample ID:** FF 3 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 3:33:29 PM

**Lab SampleID:** 240119002-004 **Collection Date:** 1/18/2024 4:25:00 AM  
**Client Sample ID:** FF 4 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 3:37:05 PM

**Lab SampleID:** 240119002-005 **Collection Date:** 1/18/2024 4:26:00 AM  
**Client Sample ID:** FF 5 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	7.9	1.0		µg/L	1	1/24/2024 3:40:40 PM

# Adirondack Environmental Services, Inc

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-006 **Collection Date:** 1/18/2024 4:26:00 AM  
**Client Sample ID:** FF 6 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	10.5	1.0		µg/L	1	1/24/2024 3:44:16 PM

**Lab SampleID:** 240119002-007 **Collection Date:** 1/18/2024 4:28:00 AM  
**Client Sample ID:** FF 7 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	1.7	1.0		µg/L	1	1/24/2024 3:59:30 PM

**Lab SampleID:** 240119002-008 **Collection Date:** 1/18/2024 4:28:00 AM  
**Client Sample ID:** FF 8 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	1.9	1.0		µg/L	1	1/24/2024 4:03:06 PM

**Lab SampleID:** 240119002-009 **Collection Date:** 1/18/2024 4:29:00 AM  
**Client Sample ID:** FF 9 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 4:06:42 PM

**Lab SampleID:** 240119002-010 **Collection Date:** 1/18/2024 4:29:00 AM  
**Client Sample ID:** FF 10 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 4:10:18 PM

# Adirondack Environmental Services, Inc

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-011 **Collection Date:** 1/18/2024 4:31:00 AM  
**Client Sample ID:** FF 11 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead ND 1.0 µg/L 1 1/24/2024 4:13:53 PM

**Lab SampleID:** 240119002-012 **Collection Date:** 1/18/2024 4:32:00 AM  
**Client Sample ID:** FF 12 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead ND 1.0 µg/L 1 1/24/2024 4:24:39 PM

**Lab SampleID:** 240119002-013 **Collection Date:** 1/18/2024 4:33:00 AM  
**Client Sample ID:** FF 13 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead 11.0 1.0 µg/L 1 1/24/2024 4:28:14 PM

**Lab SampleID:** 240119002-014 **Collection Date:** 1/18/2024 4:33:00 AM  
**Client Sample ID:** FF 14 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead 4.2 1.0 µg/L 1 1/24/2024 4:31:49 PM

**Lab SampleID:** 240119002-015 **Collection Date:** 1/18/2024 4:35:00 AM  
**Client Sample ID:** FF 15 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead 2.4 1.0 µg/L 1 1/24/2024 4:42:35 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order: 240119002**  
**PO#: 52078**

**Lab SampleID:** 240119002-016 **Collection Date:** 1/18/2024 4:35:00 AM  
**Client Sample ID:** FF 16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	3.4	1.0		µg/L	1	1/24/2024 4:46:10 PM

**Lab SampleID:** 240119002-017 **Collection Date:** 1/18/2024 4:36:00 AM  
**Client Sample ID:** FF 17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 4:49:46 PM

**Lab SampleID:** 240119002-018 **Collection Date:** 1/18/2024 4:36:00 AM  
**Client Sample ID:** FF 18 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 4:53:23 PM

**Lab SampleID:** 240119002-019 **Collection Date:** 1/18/2024 4:37:00 AM  
**Client Sample ID:** FF 19 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	2.4	1.0		µg/L	1	1/24/2024 4:56:59 PM

**Lab SampleID:** 240119002-020 **Collection Date:** 1/18/2024 4:38:00 AM  
**Client Sample ID:** FF 20 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	3.3	1.0		µg/L	1	1/24/2024 5:00:35 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-021 **Collection Date:** 1/18/2024 4:39:00 AM  
**Client Sample ID:** FF 21 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 5:11:21 PM

**Lab SampleID:** 240119002-022 **Collection Date:** 1/18/2024 4:39:00 AM  
**Client Sample ID:** FF 22 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 5:29:18 PM

**Lab SampleID:** 240119002-023 **Collection Date:** 1/18/2024 4:40:00 AM  
**Client Sample ID:** FF 23 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **1.7** 1.0 µg/L 1 1/24/2024 5:32:53 PM

**Lab SampleID:** 240119002-024 **Collection Date:** 1/18/2024 4:42:00 AM  
**Client Sample ID:** FF 24 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **5.0** 1.0 µg/L 1 1/24/2024 5:36:29 PM

**Lab SampleID:** 240119002-025 **Collection Date:** 1/18/2024 4:42:00 AM  
**Client Sample ID:** FF 25 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **12.9** 1.0 µg/L 1 1/24/2024 5:40:05 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-026 **Collection Date:** 1/18/2024 4:43:00 AM  
**Client Sample ID:** FF 26 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
( Prep: - 1/19/2024 )  
Lead 8.0 1.0 µg/L 1 1/24/2024 5:43:42 PM

**Lab SampleID:** 240119002-027 **Collection Date:** 1/18/2024 4:44:00 AM  
**Client Sample ID:** FF 27 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
( Prep: - 1/19/2024 )  
Lead 3.2 1.0 µg/L 1 1/24/2024 5:47:18 PM

**Lab SampleID:** 240119002-028 **Collection Date:** 1/18/2024 4:47:00 AM  
**Client Sample ID:** FF 28A **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
( Prep: - 1/19/2024 )  
Lead 2.3 1.0 µg/L 1 1/24/2024 5:50:54 PM

**Lab SampleID:** 240119002-029 **Collection Date:** 1/18/2024 4:47:00 AM  
**Client Sample ID:** FF 28B **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
( Prep: - 1/19/2024 )  
Lead 2.9 1.0 µg/L 1 1/24/2024 5:54:30 PM

**Lab SampleID:** 240119002-030 **Collection Date:** 1/18/2024 4:47:00 AM  
**Client Sample ID:** FF 28C **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
( Prep: - 1/19/2024 )  
Lead 2.1 1.0 µg/L 1 1/24/2024 5:58:06 PM



**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-031 **Collection Date:** 1/18/2024 4:49:00 AM  
**Client Sample ID:** FF 29 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 6:08:52 PM

**Lab SampleID:** 240119002-032 **Collection Date:** 1/18/2024 4:50:00 AM  
**Client Sample ID:** FF 30 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 6:19:39 PM

**Lab SampleID:** 240119002-033 **Collection Date:** 1/19/2024 4:52:00 AM  
**Client Sample ID:** FF 31 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **5.6** 1.0 µg/L 1 1/24/2024 6:23:15 PM

**Lab SampleID:** 240119002-034 **Collection Date:** 1/19/2024 4:52:00 AM  
**Client Sample ID:** FF 32 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **6.2** 1.0 µg/L 1 1/24/2024 6:26:51 PM

**Lab SampleID:** 240119002-035 **Collection Date:** 1/18/2024 4:54:00 AM  
**Client Sample ID:** FF 33 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 6:30:27 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-036 **Collection Date:** 1/18/2024 4:54:00 AM  
**Client Sample ID:** FF 34 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 6:34:03 PM

**Lab SampleID:** 240119002-037 **Collection Date:** 1/18/2024 4:56:00 AM  
**Client Sample ID:** FF 35 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 6:37:40 PM

**Lab SampleID:** 240119002-038 **Collection Date:** 1/18/2024 4:56:00 AM  
**Client Sample ID:** FF 36 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 6:41:16 PM

**Lab SampleID:** 240119002-039 **Collection Date:** 1/18/2024 4:58:00 AM  
**Client Sample ID:** FF 37 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **8.5** 1.0 µg/L 1 1/24/2024 6:52:02 PM

**Lab SampleID:** 240119002-040 **Collection Date:** 1/18/2024 4:58:00 AM  
**Client Sample ID:** FF 38 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **5.8** 1.0 µg/L 1 1/24/2024 6:55:38 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-041 **Collection Date:** 1/18/2024 4:59:00 AM  
**Client Sample ID:** FF 39 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	10.1	1.0		µg/L	1	1/24/2024 7:06:27 PM

**Lab SampleID:** 240119002-042 **Collection Date:** 1/18/2024 5:01:00 AM  
**Client Sample ID:** FF 40 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 7:17:16 PM

**Lab SampleID:** 240119002-043 **Collection Date:** 1/18/2024 5:04:00 AM  
**Client Sample ID:** FF 41 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 7:20:52 PM

**Lab SampleID:** 240119002-044 **Collection Date:** 1/18/2024 5:05:00 AM  
**Client Sample ID:** FF 42 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 7:24:28 PM

**Lab SampleID:** 240119002-045 **Collection Date:** 1/18/2024 5:05:00 AM  
**Client Sample ID:** FF 43 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 <span style="float: right;">Analyst: SM</span>						
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 7:35:15 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-046  
**Client Sample ID:** FF 44

**Collection Date:** 1/18/2024 5:07:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )  
 Lead ND

1.0 µg/L 1 1/24/2024 7:38:52 PM

**Lab SampleID:** 240119002-047  
**Client Sample ID:** FF 45

**Collection Date:** 1/18/2024 5:07:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )  
 Lead ND

1.0 µg/L 1 1/24/2024 7:42:28 PM

**Lab SampleID:** 240119002-048  
**Client Sample ID:** FF 46

**Collection Date:** 1/18/2024 5:08:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )  
 Lead ND

1.0 µg/L 1 1/24/2024 7:46:05 PM

**Lab SampleID:** 240119002-049  
**Client Sample ID:** FF 47

**Collection Date:** 1/18/2024 5:09:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )  
 Lead ND

1.0 µg/L 1 1/24/2024 7:49:42 PM

**Lab SampleID:** 240119002-050  
**Client Sample ID:** FF 48

**Collection Date:** 1/18/2024 5:09:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )  
 Lead ND

1.0 µg/L 1 1/24/2024 7:53:18 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-051 **Collection Date:** 1/18/2024 5:12:00 AM  
**Client Sample ID:** FF 49 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 7:56:55 PM

**Lab SampleID:** 240119002-052 **Collection Date:** 1/18/2024 5:12:00 AM  
**Client Sample ID:** FF 50 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 8:07:45 PM

**Lab SampleID:** 240119002-053 **Collection Date:** 1/18/2024 5:13:00 AM  
**Client Sample ID:** FF 51 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 8:18:31 PM

**Lab SampleID:** 240119002-054 **Collection Date:** 1/18/2024 5:13:00 AM  
**Client Sample ID:** FF 52 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 8:22:08 PM

**Lab SampleID:** 240119002-055 **Collection Date:** 1/18/2024 5:17:00 AM  
**Client Sample ID:** FF 53 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead **ND** 1.0 µg/L 1 1/24/2024 8:25:45 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-056 **Collection Date:** 1/18/2024 5:17:00 AM  
**Client Sample ID:** FF 54 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead ND 1.0 µg/L 1 1/24/2024 8:29:22 PM

**Lab SampleID:** 240119002-057 **Collection Date:** 1/18/2024 5:17:00 AM  
**Client Sample ID:** FF 54B **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead ND 1.0 µg/L 1 1/24/2024 8:32:59 PM

**Lab SampleID:** 240119002-058 **Collection Date:** 1/18/2024 5:19:00 AM  
**Client Sample ID:** FF 55 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead 1.5 1.0 µg/L 1 1/24/2024 8:36:36 PM

**Lab SampleID:** 240119002-059 **Collection Date:** 1/18/2024 5:19:00 AM  
**Client Sample ID:** FF 56 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead ND 1.0 µg/L 1 1/24/2024 8:40:13 PM

**Lab SampleID:** 240119002-060 **Collection Date:** 1/18/2024 5:19:00 AM  
**Client Sample ID:** FF 57 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  
 Lead 1.3 1.0 µg/L 1 1/24/2024 8:43:50 PM

# Adirondack Environmental Services, Inc

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-061

**Collection Date:** 1/18/2024 5:20:00 AM

**Client Sample ID:** FF 58

**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )

Lead	2.4	1.0		µg/L	1	1/24/2024 9:01:50 PM
------	-----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-062

**Collection Date:** 1/18/2024 5:20:00 AM

**Client Sample ID:** FF 59

**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )

Lead	ND	1.0		µg/L	1	1/24/2024 9:12:41 PM
------	----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-063

**Collection Date:** 1/18/2024 5:23:00 AM

**Client Sample ID:** FF 60

**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )

Lead	1.6	1.0		µg/L	1	1/24/2024 9:16:18 PM
------	-----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-064

**Collection Date:** 1/18/2024 5:23:00 AM

**Client Sample ID:** FF 61

**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )

Lead	ND	1.0		µg/L	1	1/24/2024 9:19:56 PM
------	----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-065

**Collection Date:** 1/18/2024 5:24:00 AM

**Client Sample ID:** FF 62

**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

( Prep: - 1/19/2024 )

Lead	1.2	1.0		µg/L	1	1/24/2024 9:23:33 PM
------	-----	-----	--	------	---	----------------------

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-066 **Collection Date:** 1/18/2024 5:27:00 AM  
**Client Sample ID:** FF 63 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	1.9	1.0		µg/L	1	1/24/2024 9:27:10 PM
------	-----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-067 **Collection Date:** 1/18/2024 5:27:00 AM  
**Client Sample ID:** FF 64 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	1.6	1.0		µg/L	1	1/24/2024 9:30:47 PM
------	-----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-068 **Collection Date:** 1/18/2024 5:27:00 AM  
**Client Sample ID:** FF 65 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	1.1	1.0		µg/L	1	1/24/2024 9:34:24 PM
------	-----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-069 **Collection Date:** 1/18/2024 5:28:00 AM  
**Client Sample ID:** FF 66 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	ND	1.0		µg/L	1	1/24/2024 9:45:12 PM
------	----	-----	--	------	---	----------------------

**Lab SampleID:** 240119002-070 **Collection Date:** 1/18/2024 5:28:00 AM  
**Client Sample ID:** FF 67 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	ND	1.0		µg/L	1	1/24/2024 9:48:49 PM
------	----	-----	--	------	---	----------------------



**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-071 **Collection Date:** 1/18/2024 5:31:00 AM  
**Client Sample ID:** FF 68 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	2.1	1.0		µg/L	1	1/24/2024 9:52:26 PM

**Lab SampleID:** 240119002-072 **Collection Date:** 1/18/2024 5:31:00 AM  
**Client Sample ID:** FF 69 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/24/2024 10:03:18 PM

**Lab SampleID:** 240119002-073 **Collection Date:** 1/18/2024 5:31:00 AM  
**Client Sample ID:** FF 70 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	1.2	1.0		µg/L	1	1/24/2024 10:06:55 PM

**Lab SampleID:** 240119002-074 **Collection Date:** 1/18/2024 5:37:00 AM  
**Client Sample ID:** FF 71 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	2.6	1.0		µg/L	1	1/24/2024 10:10:33 PM

**Lab SampleID:** 240119002-075 **Collection Date:** 1/18/2024 5:37:00 AM  
**Client Sample ID:** FF 72 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	3.6	1.0		µg/L	1	1/24/2024 10:14:10 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-076  
**Client Sample ID:** FF 73

**Collection Date:** 1/18/2024 5:37:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

( Prep: - 1/19/2024 )

Analyst: SM

Lead	6.0	1.0		µg/L	1	1/24/2024 10:17:48 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-077  
**Client Sample ID:** FF 74

**Collection Date:** 1/18/2024 5:40:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

( Prep: - 1/19/2024 )

Analyst: SM

Lead	2.7	1.0		µg/L	1	1/24/2024 10:28:35 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-078  
**Client Sample ID:** FF 75

**Collection Date:** 1/18/2024 5:40:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

( Prep: - 1/19/2024 )

Analyst: SM

Lead	15.9	1.0	X	µg/L	1	1/24/2024 10:32:13 PM
------	------	-----	---	------	---	-----------------------

**Lab SampleID:** 240119002-079  
**Client Sample ID:** FF 76

**Collection Date:** 1/18/2024 5:41:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

( Prep: - 1/19/2024 )

Analyst: SM

Lead	7.1	1.0		µg/L	1	1/24/2024 10:35:50 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-080  
**Client Sample ID:** FF 77

**Collection Date:** 1/18/2024 5:41:00 AM  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

( Prep: - 1/19/2024 )

Analyst: SM

Lead	7.4	1.0		µg/L	1	1/24/2024 10:39:28 PM
------	-----	-----	--	------	---	-----------------------

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-081 **Collection Date:** 1/18/2024 5:44:00 AM  
**Client Sample ID:** FF 78 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	2.6	1.0		µg/L	1	1/24/2024 10:50:21 PM

**Lab SampleID:** 240119002-082 **Collection Date:** 1/18/2024 5:44:00 AM  
**Client Sample ID:** FF 79 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	2.4	1.0		µg/L	1	1/24/2024 11:01:14 PM

**Lab SampleID:** 240119002-083 **Collection Date:** 1/18/2024 5:45:00 AM  
**Client Sample ID:** FF 80 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	6.3	1.0		µg/L	1	1/24/2024 11:12:02 PM

**Lab SampleID:** 240119002-084 **Collection Date:** 1/18/2024 5:46:00 AM  
**Client Sample ID:** FF 81 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	2.2	1.0		µg/L	1	1/24/2024 11:15:40 PM

**Lab SampleID:** 240119002-085 **Collection Date:** 1/18/2024 5:46:00 AM  
**Client Sample ID:** FF 82 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	14.9	1.0		µg/L	1	1/24/2024 11:19:17 PM

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-086 **Collection Date:** 1/18/2024 5:47:00 AM  
**Client Sample ID:** FF 83 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	1.2	1.0		µg/L	1	1/24/2024 11:22:55 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-087 **Collection Date:** 1/18/2024 5:47:00 AM  
**Client Sample ID:** FF 84 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	8.0	1.0		µg/L	1	1/24/2024 11:26:33 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-088 **Collection Date:** 1/18/2024 5:47:00 AM  
**Client Sample ID:** FF 85 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	1.9	1.0		µg/L	1	1/24/2024 11:30:11 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-089 **Collection Date:** 1/18/2024 5:51:00 AM  
**Client Sample ID:** FF 86 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	2.7	1.0		µg/L	1	1/24/2024 11:33:49 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-090 **Collection Date:** 1/18/2024 5:51:00 AM  
**Client Sample ID:** FF 87 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	9.9	1.0		µg/L	1	1/24/2024 11:37:26 PM
------	-----	-----	--	------	---	-----------------------

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
 Forts Ferry

**LabWork Order:** 240119002  
**PO#:** 52078

**Lab SampleID:** 240119002-091 **Collection Date:** 1/18/2024 5:51:00 AM  
**Client Sample ID:** FF 88 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	3.4	1.0		µg/L	1	1/24/2024 11:41:04 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-092 **Collection Date:** 1/18/2024 5:54:00 AM  
**Client Sample ID:** FF 89 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	2.3	1.0		µg/L	1	1/24/2024 11:59:08 PM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-093 **Collection Date:** 1/18/2024 5:54:00 AM  
**Client Sample ID:** FF 90 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	1.6	1.0		µg/L	1	1/25/2024 12:02:47 AM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-094 **Collection Date:** 1/18/2024 5:54:00 AM  
**Client Sample ID:** FF 91 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	5.2	1.0		µg/L	1	1/25/2024 12:06:25 AM
------	-----	-----	--	------	---	-----------------------

**Lab SampleID:** 240119002-095 **Collection Date:** 1/18/2024 5:58:00 AM  
**Client Sample ID:** FF 92 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM  
 ( Prep: - 1/19/2024 )  

Lead	2.1	1.0		µg/L	1	1/25/2024 12:10:03 AM
------	-----	-----	--	------	---	-----------------------

**Adirondack Environmental Services, Inc**

Date: 25-Jan-24

**CLIENT:** North Colonie Central School District  
**Project:** Lead in PW  
Forts Ferry

**LabWork Order: 240119002**  
**PO#: 52078**

**Lab SampleID:** 240119002-096      **Collection Date:** 1/18/2024 5:58:00 AM  
**Client Sample ID:** FF 93      **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	6.9	1.0		µg/L	1	1/25/2024 12:13:42 AM

**Lab SampleID:** 240119002-097      **Collection Date:** 1/18/2024 5:58:00 AM  
**Client Sample ID:** FF 94      **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	5.4	1.0		µg/L	1	1/25/2024 12:17:20 AM

**Lab SampleID:** 240119002-098      **Collection Date:** 1/18/2024 6:02:00 AM  
**Client Sample ID:** FF 95      **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
( Prep: - 1/19/2024 )						
Lead	ND	1.0		µg/L	1	1/25/2024 12:20:58 AM