

2023-2025 Lead Water Testing**LATHAM
RIDGE****DATE:
1/23/2024**

	Location	Time	Result	Acceptable range ug/l
	Room 14 sink	533	4.4	≤ 5.0
	Room 14 bubbler	533	8.3	≤ 5.0
	Room 16 bubbler	534	6.9	≤ 5.0
	Room 3 sink	537	ND	≤ 5.0
	Room 4 sink	538	ND	≤ 5.0
	Room 7 sink	527	3.2	≤ 5.0
	Room 10 bathroom sink	541	1.2	≤ 5.0