

**2023-2025 Lead Water Testing
Loudonville**

**DATE:
1/23/2024**

Sample #	Location	Time	Result	Acceptable range Pb
LVkitch2RT	Kitchen Serving Line sink	511	6.6	≤ 5.0
Lvgymhallrt	Gym water fountain - hallway	512	8.4	≤ 5.0
LVbath2rt	Men's Bathroom - second bthrm	513	3.3	≤ 5.0
LV29sink2rt	Room29 Sink	517	1.8	≤ 5.0
LV21sink2rt	Room 21 Bath	515	3.6	≤ 5.0
LV22sink2rt	Room 22 Sink (bathroom)	515	8.6	≤ 5.0

exceedances posted NOT FOR DRINKING

Gym fountain parts replace with new. Due to exceedance unit is not in service.