

**2023-2025 Lead Water Testing  
Loudonville**

**DATE:**  
12/28/2023

Sample #	Location	Time	Result	Acceptable range Pb
LCcafeRT	Café	518	2.6	≤ 5.0
LVkitchRT	Kitchen Serving Line sink	519	11	≤ 5.0
	Gym water fountain - hallway	Fountain to be replaced		≤ 5.0
	fountain the gym	Fountain removed		≤ 5.0
LVbathRT	Men's Bathroom - second bthrm	520	5.3	≤ 5.0
	Fountain by all gender bath	Fountain removed		≤ 5.0
LV29RT	Room29 Sink	523	9.1	≤ 5.0
	ftn in hall by room 38	Fountain removed		≤ 5.0
LV21RT	Room 21 Bath	525	8.8	≤ 5.0
LV22RT	Room 22 Sink (bathroom)	526	6.6	≤ 5.0

exceedances posted NOT FOR DRINKING