

2023-2025 Lead \Water Testing**DATE:** _____**Ice machines**

Sample #	Location	Time	Result Pb	Acceptable range Pb
SHS1	SHS kitchen ice machine	11:00	NOT DETECTED	≤ 5
SHS2	SHS Fgym ice machine	11:05	NOT DETECTED	≤ 5
SJHS1	SJH gym ice machine	11:17	NOT DETECTED	≤ 5