

2023-2025 Lead Water Testing**SHAKER
HIGH****DATE:**
4/15/2024

Sample #	Location	Time	Result	Acceptable range Pb
13	Steamer water	442	10.8	≤ 5
50	PT regular sink	527	12.2	≤ 5
51	PT slop sink	527	21.1	≤ 5
59	H gym girls LR handicap BR	507	6.8	≤ 5
74	Pool bathroom sink	538	6.9	≤ 5